

Patrick Bird / Drainology
823 PIER AVE #A
SANTA MONICA, CA 90405
(310)398-2007
drainology@yahoo.com

INVOICE

BILL TO

Maria Rowe
247 Windward

SHIP TO

Maria Rowe
247 Windward

INVOICE # 4348**DATE 03/02/2016****ACTIVITY****AMOUNT****Services**

250.00

INSPECTION OF MAIN SEWER LINE:

Inspected the sewer line from the house to the city sewer. The city sewer is located in the alley in the rear.

Entered the sewer line through a 4" ABS clean out the East side of the house. The sewer line runs along the side of the house then under the back yard. The pipe along the side of the house and back yard is 4" ABS pipe to the property line.

From the property line to the connection to the city sewer the pipe is 6" Vitrified Clay pipe. There is no visible problems in the ABS pipe.

The Clay section has some very heavy roots inside the pipe. These roots have to be removed so we can see the walls of the 6" pipe. The best way to remove roots from the 6" pipe is with a Hydro jetter, this will remove all the roots.

The usual cost for Hydro jetting is \$450.00. We will do this for the amount of \$300.00 from the clean out to near the alley.

PAYMENT

250.00

BALANCE DUE

\$0.00